

Notes:

FHWA APPROVAL

**DATE**: 10-17-78

I. The conduit and junction box are to be placed only when indicated in the Superstructure "Typical Section." If  $\mathfrak L$  to  $\mathfrak L$  of end junction boxes exceed 200', then additional junction boxes shall be placed in parapet, between control joints, so that the maximum distance between boxes is 200'. Junction boxes for light standards, may be utilized. All junction boxes to have  $\frac{1}{2}$ " $\varphi$  drain at drain at low point of box.

2. Conduit may be either PVC or galvanized pipe.

	APPROVAL	
OFFICE OF STR		
	DATE: 4/13/78	
	REVIS	SIONS
	REVIS SHA	SIONS FHWA
	SHA	

4-16-08

STATE OF MARYLAND
DEPARTMENT OF TRANSPORTATION
STATE HIGHWAY ADMINISTRATION
OFFICE OF STRUCTURES

2 & 3 of 4.

PARAPET CONTROL JOINT AND SINGLE CONDUIT PLACEMENT WITH 34" F-SHAPE PARAPET AND PARAPET WITH SIDEWALK

**STANDARD NO.** BR-SS(6.09)-05-70A

SHEET \_\_\_\_ OF\_4

SUPER-CONCRETE WOR